



# 中国国家强制性产品认证证书

证书编号: 2014010309745314

## 委托人名称、地址

Schneider Electric Korea Ltd.  
(Sang-am-dong, 14F Kbiz DMC Tower), 189 Seongam-ro, Mapo-gu, Seoul, Korea

## 生产者(制造商)名称、地址

Schneider Electric Korea Ltd.  
(Sang-am-dong, 14F Kbiz DMC Tower), 189 Seongam-ro, Mapo-gu, Seoul, Korea

## 生产企业名称、地址

Schneider Electric Korea Ltd.  
63-5 Seokam-ro 1-gil, Iksan City, Jun Book, Korea

## 产品名称和系列、规格、型号

### 电子式过载继电器

EOCRDS1(T)、EOCRDS3(T)、EOCRSE2;  $U_i$ :690V;  $U_e$ :AC690V;  $I_e$ [EOCRDS1(T)]:  
0.5A~6A、3A~30A;  $I_e$ [EOCRDS3(T)、EOCRSE2]: 0.5A~6A、3A~30A、5A~60A; 脱扣级  
别: 2E, 3E, 5E, 10E; 2P (EOCRSE2), 3P [EOCRDS1(T)、EOCRDS3(T)]; IP20; 配用的辅助  
触头: 1NO1NC;  $I_{th}$ :3A; AC-15:250V/3A; DC-13:30V/3A; 型号解释详见附件

## 产品标准和技术要求

GB 14048.4-2010

上述产品符合强制性产品认证实施规则

CNCA-C03-02:2014的要求, 特发此证。

发证日期: 2015年01月15日

有效期至: 2019年12月31日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书, 证书首次颁发日期: 2014年12月31日

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:

中国质量认证中心

中国·北京·南四环西路188号9区 100070

<http://www.cqc.com.cn>



Q 1073070



# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2014010309745314

## NAME AND ADDRESS OF THE APPLICANT

Schneider Electric Korea Ltd.  
(Sang-am-dong, 14F Kbiz DMC Tower), 189 Seongam-ro, Mapo-gu, Seoul, Korea

## NAME AND ADDRESS OF THE MANUFACTURER

Schneider Electric Korea Ltd.  
(Sang-am-dong, 14F Kbiz DMC Tower), 189 Seongam-ro, Mapo-gu, Seoul, Korea

## NAME AND ADDRESS OF THE FACTORY

Schneider Electric Korea Ltd.  
63-5 Seokam-ro 1-gil, Iksan City, Jun Book, Korea

## NAME, MODEL AND SPECIFICATION

Electronic Overload Relay

EOCRDS1(T)、EOCRDS3(T)、EOCRSE2; Ui:690V; Ue:AC690V; Ie[EOCRDS1(T)]:  
0.5A~6A、3A~30A; Ie[EOCRDS3(T)、EOCRSE2]: 0.5A~6A、3A~30A、5A~60A;  
Tripping class: 2E, 3E, 5E, 10E; 2P(EOCRSE2), 3P[EOCRDS1(T)、EOCRDS3  
(T)]; IP20; Attached Auxiliary Contacts: 1NO1NC; Ith:3A; AC-15:250V/3A; DC-  
13:30V/3A; See the Appendix for type explanation

## THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 14048.4-2010

This is to certify that the above mentioned products have met the requirements of implementation rules for compulsory certification(REF NO. CNCA-C03-02:2014).

Date of issue: Jan.15,2015      Date of expiry: Dec.31,2019

Validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original certification: Dec.31,2014

This certificate can be verified through CNCA's website: [www.cnca.gov.cn](http://www.cnca.gov.cn)



President:

Wang Kejiao



**CHINA QUALITY CERTIFICATION CENTRE**

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>

Q 1073070



# 中国国家强制性产品认证证书

附录:

第 1 页 共 1 页

证书编号: 2014010309745314

纸号: 1073070

型号的解释:

EOCR        
① ② ③ ④ ⑤ ⑥

No	Type	Meaning
①	Model	DS1 逆相, 缺相, 反时限
		DS3 逆相, 缺相, 定时限
		SE2 定时限
②	Terminal	T Terminal type 螺钉端子连接
		Blank Non-terminal type 无螺钉端子(穿孔连接)
③	Standard	05 Ie:0.5A~6A
		30 Ie:3A~30A
		60 Ie:5A~60A
④	Fail safety	N Fail safe ON 有故障判断
		R Fail safe OFF 无故障判断
		Blank 可设定 N Type 或 R Type
⑤	Power Supply	S AC/DC (24~240)V
		W AC (380~440)V
⑥	Product Usage	Q 出口产品
		Blank 本地销售产品

注: 此附录与证书同时使用时有效。



主任:

中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>

